



# 产品认证证书

证书编号：CQC16003142025

## 申请人名称及地址

厦门唯恩电气有限公司  
厦门市同安区大同街道城北工业区

## 制造商名称及地址

厦门唯恩电气有限公司  
厦门市同安区大同街道城北工业区

## 生产企业名称及地址

厦门唯恩电气有限公司(V024557)  
厦门市同安区朝元路城北工业区 759-3

## 产品名称和系列、规格、型号

电连接器

型号见附件

## 产品标准和技术要求

GB/T34989-2017

## 认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC11-462222-2011 认证规则的要求，特发此证。

发证日期：2018 年 07 月 17 日

本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2016 年 04 月 11 日

主任：\_\_\_\_\_



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0119161



# PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC16003142025

## NAME AND ADDRESS OF THE APPLICANT

Xiamen WAIN Electrical Co., Ltd.  
Chengbei Industrial Zone, Datong Street, Tong'an District, Xiamen City

## NAME AND ADDRESS OF THE MANUFACTURER

Xiamen WAIN Electrical Co., Ltd.  
Chengbei Industrial Zone, Datong Street, Tong'an District, Xiamen City

## NAME AND ADDRESS OF THE FACTORY

Xiamen WAIN Electrical Co., Ltd. (V024557)  
No.759-3 Chengbei Industrial Zone, Chaoyuan Road, Tong'an District, Xiamen

## PRODUCT NAME, MODEL AND SPECIFICATION

Electrical Connectors  
Model See Appendix

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T34989-2017

## TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462222-2011 .

Valid from: Jul.17,2018

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body.

Date of original issued: Apr.11,2016

President: \_\_\_\_\_

Wang Kejiao



## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China  
<http://www.cqc.com.cn>

C 0119161



# 产品认证证书

附录:

第 1 页 共 1 页

证书编号: CQC16003142025

纸号: 119161

产品名称 (中文):

电连接器

规格和型号:

HE-048-MSS+HE-048-FSS 16A 500V IP65  
HME-005-MS+HME-005-FS 16A 400V IP65;  
HE-006-MS+HE-006-FS 16A 500V IP65;  
HE-006-MSS+HE-006-FSS 16A 500V IP65;  
HE-010-MS+HE-010-FS 16A 500V IP65;  
HE-010-MSS+HE-010-FSS 16A 500V IP65;  
HE-016-MS+HE-016-FS 16A 500V IP65;  
HE-016-MSS+HE-016-FSS 16A 500V IP65;  
HE-024-MS+HE-024-FS 16A 500V IP65;  
HE-024-MSS+HE-024-FSS 16A 500V IP65;  
HE-032-MS+HE-032-FS 16A 500V IP65;  
HE-032-MSS+HE-032-FSS 16A 500V IP65;  
HE-048-MS+HE-048-FS 16A 500V IP65。

无分断能力 固定连接器 I类 不带联锁 螺纹端子连接 -40T125 污染等级 3 无负载 500  
次操作循环 灼热丝 850℃ 球压 125℃ 针焰 10s PTI175

注: 此附录与证书同时使用时有效。

主任: \_\_\_\_\_



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>